

DAIKIN ONE+ and ONE TOUCH HOMEOWNER SETTINGS MENU OUTLINE
 (based on v3.2.19 software for VRV and mini/multi-split systems)

Level 1	Level 2	Level 3	Level 4	Level 5	Level 6		
system mode	auto (cool & heat) -or- master controlled	(The "master controlled" option appears only for VRV systems, and only if another thermostat is selected as the master.)					
	cool						
	heat						
	off						
	emergency heat	(if aux heat source available)					
fan	cooling fan speed	auto	(depends on indoor unit)				
		low	(depends on indoor unit)				
		medium low	(depends on indoor unit)				
		medium	(depends on indoor unit)				
		medium high	(depends on indoor unit)				
		high	(depends on indoor unit)				
	cooling vertical position	oscillate	(depends on indoor unit)				
		fixed	(depends on indoor unit)				
		position	(only VRV, depends on indoor unit)				
	cooling horizontal position	oscillate	(depends on indoor unit)				
		fixed	(depends on indoor unit)				
	heating fan speed	auto	(depends on indoor unit)				
		low	(depends on indoor unit)				
		medium low	(depends on indoor unit)				
		medium	(depends on indoor unit)				
		medium high	(depends on indoor unit)				
heating vertical position	oscillate	(depends on indoor unit)					
	fixed	(depends on indoor unit)					
	position	(only VRV, depends on indoor unit)					
heating horizontal position	oscillate	(depends on indoor unit)					
	fixed	(depends on indoor unit)					
schedule	paused until...	(if schedule paused)					
	on						
	off						
	edit schedule (appears when schedule on)	Sunday Monday Tuesday Wednesday Thursday Friday Saturday	start time heat setpoint/cool setpoint	(1st schedule event name)	day (weekday of event)		
					time	(time selection)	
					label	(text entry)	
					action	set temperature (selection of heat and cool setpoints)	
					temperature		
					(2nd schedule event name) start time heat setpoint/cool setpoint	(same options as 1st schedule event)	
						(up to 6 schedule events)	
	copy day						
	add event						
override duration (appears when schedule on)	until next event						
	for one hour						
	for two hours						
	for four hours						
	for eight hours						
away	on (radio button)						
	off (radio button)						
	away temperatures	setpoints)					
	receive geofencing events (checkbox)						
display	language	english					
		español					
		française					
	degree units	fahrenheit					
		celsius					
	brightness	50 - 100% scale					
	night mode	night mode (check box)					
		from (time selection) to (time selection)					
	use large font (check box)						
	use light bar (check box)						
	screen saver	off					
blank screen							
analog clock digital clock							
screen cleaning	touch screen is disabled from screen cleaning (30s)						
lock	Enter a 4-digit PIN...	(number entry)					

sound	use sound (check box)	(not on the Touch thermostat)				
reminders	(list of installed filters with reminders menu for each)	Off				
		1 month				
		2 months				
		3 months				
		4 months				
		6 months				
		12 months				
		restart timer	cancel			
		continue				
date & time	time zone	(list of North America time zones with radio button selection)				
	month/date/year	(selection with spinner, for display only if connected to internet)				
	hour/minute/am or pm	(selection with spinner, for display only if connected to internet)				
	use 24-hour time format (checkbox)					
wifi	use wifi (checkbox)					
	networks (current network)	network list	legal notices	terms of use	(text)	
				privacy policy	(text)	
				end user license agreement	(text)	
				decline		
			accept			
			(password text box)			
			show password (checkbox)	(if protected network)		
			advanced settings	use dhcp (checkbox)		(screen appears after legal notices accepted)
	connect per agreed terms (and) Done	(initiates connection to wifi network)				
	searching for networks (or) search again					
	internet connected (check)					
Daikin One Cloud connected (check)						
legal notices	terms of use	(text)				
	privacy policy	(text)				
	end user license agreement	(text)				
restart thermostat (if internet but no cloud)						
account	(6-digit account code if app not connected)					
	(account email if app)					
	reset registration (if app connected)	cancel				
		continue				
air quality	circulate air	off				
		on				
humidity	target humidity	humidify if less than (25% - 65%)	(5% increments)			
		dehumidify if more than (35% - 75%)	(5% increments)			
	overcool to dehumidify	Overcooling allowed to dehumidify: 0°F to 3°F (0°C to 1.5°C)	(1°F or 0.5°C increments)			
		Temperature setpoint deadband: 2°F to 9°F (1°C to 5°C)	(1°F or 0.5°C increments)			
energy	demand response	use demand response (checkbox)	(only functional with local utility support)			
		When demand response signal is received:	offset temperature setpoints			
			use fixed temperature setpoints			
	response settings	setpoint offsets	Offset heat setpoints by this value: (-1°F to -7°F)			
			Offset cool setpoints by this value: (1°F to 7°F)			
		event setpoint limits	(50°F to 90°F)			
enable energy pricing (checkbox)						
price trigger (if checkbox above)	(\$0.00 to \$9.99)					
thermostat	name	main room				
		upstairs				
		downstairs				
		hallway				
		bedroom				
		kitchen				
		other				
		other name (if other selected)	(text entry)			
model ONEPLUS						
software version (x.x.x format)						
wifi address (x:x:x:x:x format)						
thermostat ID (DKN...)						
restart thermostat	cancel					

	restart thermostat	continue			
	check for update	software update found (or) no update available--dismiss			
equipment	COMMUNICATING EQUIPMENT:				
	indoor unit	(unit description)			
		model #			
		serial #			
		unit type			
	outdoor unit	(unit description)			
		model #			
		serial #			
	ADDITIONAL EQUIPMENT:				
	air quality sensor	(if installed)			
	aux heat source	(if installed)			
filter box	(if installed)				
HEPA filter	(if installed)				
standard filter	(if installed)				
dehumidifier	(if installed)				
humidifier	(if installed)				
VRV IDU sensor	(only VRV systems, if installed)				
support	Daikin Support				
	Daikin Dealer				
	cloud services	no access			
		view only			
adjust settings					
dealer edit	cancel	(i)	(4 digit pin for thermostat)		
	continue	4 digit code (text entry) unlock thermostat (or) done	(entry into commissioning screens)		